

**Table 1 Requirement for Bleaching
Power, Stable**

Sl no	Characteristic	Requirement		Method of Test, Ref to clause no in Annex A
		Grade 1	Grade 2	
(1)	(2)	(3)	Select table column (4)	(5)
i)	Available chlorine, percent by mass,Min	34.0	32.0	A-2
ii)	Stability, loss of Chlorine on the basis of initial available chlorine, Max	1/15	1/11	A-3
iii)	Moisture, percent by mass,Max	0.3	0.5	A-4
iv)	Particle size (passing through 1.70 mm IS sieve), percent by mass,Max	99.5	99.0	A-5